

Hydel Laboratories (P) Ltd. Rajendra Nagar Sahibabad, Ghaziabad
Report no - HLL/20-260923-01.
Analysis End date: 26/9/26.

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MS/CHC/Water/2026/653

Date: 05/10/26

It is certified that an inspection team headed by Dr. Ravinder Kumar MS CHC DADAR
(Name of Officer with Designation)

from Health Department
(Name of Department/Office)

inspected the L.R. Sr. Secondary School, Danda Rajpura, S.B. Nagar.
(Name & Address of the School)

on 05/10/26 and found that the L.R. Sr. Secondary School, Danda Rajpura, S.B. Nagar
(Name of School)

has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of one year (25/9/27)

Signature with Seal: [Signature]

Name: डा. रविन्द्र कुमार

Designation: विवेक-अधीक्षक
सामुदायिक स्वास्थ्य केंद्र
दादरी, गौतम बुद्ध नगर

To, L.R. Senior Secondary School,
Danda Rajpura, S.B. Nagar

(Name & Address of the Institution)



Hydel Laboratories (P) Ltd.

Plot No. 2/20, Sec - 2, Rajender Nagar, Sahibabad, Ghaziabad 201005
 ☎ 0120-4125559, 📠 9319391840 ✉ info.hydelaboratories@gmail.com
 ✉ support@hydelabs.com 🌐 Website: www.hydelabs.com

An ISO:9001:2015, ISO:14001:2015, ISO:45001:2018 Certified Laboratory

TEST REPORT

Issued To:	L.R. Senior Secondary School Daula Rajpura, Greater Noida G.B. Nagar.	Discipline:	Chemical
Description:	Drinking Water	Group:	Water
Sample Qty.:	2 Ltr. in Sealed Packed bottle.	ULR No.:	TC-118092600000636F
Sampled By:	Customer	Report No.:	HLPL/20-260923-01
Environmental Condition:	25±5°C, RH-30 to 70%	Reporting Date:	26.09.2026
		Sample Received On:	23.09.2026
		Analysis Start Date:	23.09.2026
		Analysis End Date:	26.09.2026

Page No: 01 of 01

TEST RESULTS

S. No.	TEST PARAMETERS (With unit of measurement)	TEST RESULT	TEST METHOD	REQUIREMENT AS PER IS: 10500-2012	
				ACCEPTABLE LIMIT	PERMISSIBLE LIMIT
General Parameters: -					
1.	pH Value at 25°C	7.46	IS 3025(P-11):2022	6.5 to 8.5	No Relaxation
2.	Color, CU	ND(DL-1)	IS 3025(P-4):2021	5 Max.	15 Max.
3.	Sulphate, (as SO ₄), mg/l	6.8	IS 3025(P-24/Sec-1):2022	200 Max.	400 Max.
4.	Magnesium, (as Mg), mg/l	8	IS 3025(P-46):2023	30 Max.	100 Max.
5.	Turbidity, NTU	ND(DL-1)	IS 3025(P-10):2023	1 Max.	5 Max.
6.	Total Hardness (as CaCO ₃), mg/l	68	IS 3025(P-21):2009	200 Max.	600 Max.
7.	Calcium (as Ca), mg/l	14	IS 3025(P-40):2024	75 Max.	200 Max.
8.	Chloride (as Cl), mg/l	18	IS 3025(P-32):2025	250 Max.	1000 Max.
9.	Residual Free Chlorine, mg/l	ND(DL-0.3)	IS 3025(P-26):2021	0.2 Min.	1.0 Min.
10.	Iron (as Fe), mg/l	ND(DL-0.05)	IS 3025(P-53):2024	1.0 Max.	No Relaxation
11.	Fluoride (as F), mg/l	ND(DL-0.05)	IS 3025(P-60/Sec-1):2023	1.0 Max.	1.5 Max.
12.	Total Alkalinity, mg/l	52	IS 3025(P-23):2023	200 Max.	600 Max.
13.	Total Dissolved Solid (TDS), mg/l	156	IS 3025(P-16):2023	500 Max.	2000 Max.

Note: N.D- (Not detected), Values enclosed in brackets are the detection limit.

Remarks: -The sample confirms to IS: 10500-2012 with respect to above tests only.

End of Report



Reviewed By



बिना होलोग्राम के रिपोर्ट
मान्य नहीं है



Authorized Signatory
Kum. Pooja
Senior Analyst

HLPL/QF/7.8/02

Note:-

- The result indicated only refer to the tested samples and listed parameters and do not endorse any product.
- Total liability of the laboratory is limited to the invoiced amount.
- This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- Samples received shall be destroyed after four weeks from the date of issue of the certificate unless specified otherwise.
- This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory.

Branch Office: Dehradun(UK)

Patna (Bihar)

Ranchi (Jharkhand)